



impermeabilización, aislamiento térmico y acústico
waterproofing, thermal and acoustic insulation

Castellbisbal, 11 January 2010


TO WHOM IT MAY CONCERNS

We hereby confirm that the laboratory tests concerning the soundproofing characteristics of TECSOUND products gave the following results:

Laboratory	Tested Product	Test number	Result
Applus (Spain)	TECSOUND 50 / SY 50	4.042.669	Rw = 25 dB
Applus (Spain)	TECSOUND 70 / SY 70	4.042.666	Rw = 28 dB

Measurement were carried out according UNE EN-ISO 140-3:1995

Best regards



Luigi Sapia
Area Manager Eastern Europe.
e-mail: luigi.sapia@texsa.it



C/ Ferro, 7 - Polígono Can Paletí
08755 Castellbisbal (Barcelona)
Tel. 93 635 14 00

TEXSA, S.A.
C/ Ferro, 7- Pol. Can Paletí
08755 Castellbisbal
Barcelona (Spain)
Tel. (+34) 93 635 14 00
Fax (+34) 93 635 14 80
E-mail: texsa@texsa.com
<http://www.texsa.com>